

LABORATORY DETAIL REPORT

Client: *Berrien Springs Public Schools*

KAR Project No. : **615769**

Date Reported: **12/02/16**

Project

Description : *Analysis of drinking water for lead and copper.*

Sample ID : **"DAWC"**

Sampled By : *RRB of BSPS*

Sample Date : *11/12/16*

Sample Time : *0831*

Date Received **11/17/16**

Sample Type : **SDWA**

KAR Sample No. : **615769-01**

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
<i>Prep, metals</i>	<i><1</i>	<i>NTU</i>	<i>EPA 200.7/8</i>	<i>11/21/16</i>	<i>MID</i>	
<i>Copper, total</i>	<i>1.69</i>	<i>mg/L</i>	<i>EPA 200.8</i>	<i>12/01/16</i>	<i>NHM</i>	<i>MCL*=1.3 mg/L</i>
<i>Lead, total</i>	<i><0.001</i>	<i>mg/L</i>	<i>EPA 200.8</i>	<i>11/30/16</i>	<i>NHM</i>	<i>MCL*=0.015 mg/L</i>

KAR Laboratories, Inc.

Attest: *David R. Alkem*
LABORATORY & CONSULTING SERVICES

LABORATORY DETAIL REPORT

Client: *Berrien Springs Public Schools*

KAR Project No. : **616506**

Date Reported: **12/21/16**

Project

Description : *Analysis of drinking water for lead and copper.*

Sample ID : **"DAWC-2"**

2nd Test

Sampled By : *RRB of BSPS*

Date Received **12/07/16**

Sample Date : *12/03/16*

Sample Type : **SDWA**

Sample Time : *0945*

KAR Sample No. : **616506-46**

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
<i>Prep, metals</i>	<i><1</i>	<i>NTU</i>	<i>EPA 200.7/8</i>	<i>12/09/16</i>	<i>MID</i>	
<i>Copper, total</i>	<i>1.33</i>	<i>mg/L</i>	<i>EPA 200.8</i>	<i>12/14/16</i>	<i>NHM</i>	<i>MCL=1.3 mg/L</i>
<i>Lead, total</i>	<i><0.001</i>	<i>mg/L</i>	<i>EPA 200.8</i>	<i>12/13/16</i>	<i>NHM</i>	<i>MCL=0.015 mg/L</i>

KAR Laboratories, Inc. . . .

Attest: *David R. Akem*
LABORATORY MANAGER

LABORATORY DETAIL REPORT

Client: *Berrien Springs Public Schools*

KAR Project No. : *615769*

Date Reported: *12/02/16*

Project

Description : *Analysis of drinking water for lead and copper.*

Sample ID : **"DACF"**

Sampled By : *RRB of BSPS*

Sample Date : *11/12/16*

Sample Time : *0832*

Date Received *11/17/16*

Sample Type : *SDWA*

KAR Sample No. : *615769-02*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
<i>Prep, metals</i>	<i><1</i>	<i>NTU</i>	<i>EPA 200.7/8</i>	<i>11/21/16</i>	<i>MID</i>	
<i>Copper, total</i>	<i>1.80</i>	<i>mg/L</i>	<i>EPA 200.8</i>	<i>12/01/16</i>	<i>NHM</i>	<i>MCL*=1.3 mg/L</i>
<i>Lead, total</i>	<i><0.001</i>	<i>mg/L</i>	<i>EPA 200.8</i>	<i>11/30/16</i>	<i>NHM</i>	<i>MCL*=0.015 mg/L</i>

KAR Laboratories, Inc.

Attest: 
LABORATORY DETAIL REPORT

LABORATORY DETAIL REPORT

Client: *Berrien Springs Public Schools*

KAR Project No. : **616506**

Date Reported: **12/21/16**

Project

Description : *Analysis of drinking water for lead and copper.*

Sample ID : **"DACF-2"** *2nd Test*

Sampled By : *RRB of BSPS*

Date Received **12/07/16**

Sample Date : *12/03/16*

Sample Type : **SDWA**

Sample Time : *0946*

KAR Sample No. : **616506-47**

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
<i>Prep. metals</i>	<i><1</i>	<i>NTU</i>	<i>EPA 200.7/8</i>	<i>12/09/16</i>	<i>MID</i>	
<i>Copper, total</i>	<i>1.56</i>	<i>mg/L</i>	<i>EPA 200.8</i>	<i>12/14/16</i>	<i>NHM</i>	<i>MCL=1.3 mg/L</i>
<i>Lead, total</i>	<i><0.001</i>	<i>mg/L</i>	<i>EPA 200.8</i>	<i>12/13/16</i>	<i>NHM</i>	<i>MCL=0.015 mg/L</i>

KAR Laboratories, Inc.

Attest: *David R. Walker*
LABORATORY MANAGER